

August 20, 2024

Thomas Zinser
EN Engineering
1630 Robin Circle, Suite A
Forest Hill, MD 21050

RE: BGE Catonsville Phase 15 – Gas Main Replacement
Stormwater Management Variance
Gwynns Falls Watershed
Project I.D. M240166
Tracking Number: 01-24-4175

Dear Thomas Zinser;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the installation of approximately 3,727 linear feet of gas main by cut and cover. The existing cover conditions will be re-established once the gas main is installed. Although the disturbed area is in excess of 5,000 square feet (approx. 5,590 square feet), there will be no increase in impervious area or runoff resulting from the project.

Please contact Vearle Cochran, P.E. at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Kritty Udhin, P.E., Manager
Stormwater Management

KU:vdc