

July 3, 2024

Ariadna Risher
AECOM
7 Saint Paul Street, 17th floor
Baltimore, MD 21202

RE: Dundalk Avenue Force Main Replacement
Stormwater Management Variance
Baltimore Harbor Watershed
Project I.D. M240176
Tracking Number: 07-24-4152

Dear Ariadna Risher;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the replacement of approximately 2,250 LF of force main by cut and cover. The existing cover conditions will be re-established once the force main is installed. Although the disturbed area is in excess of 5,000 square feet (approximately 11,460 SF), there will be no increase in impervious area or runoff resulting from the project.

Please contact Vearle Cochran, P.E. at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Brady Locher, Deputy Director

BL:vdc