

June 5, 2024

Patrick Richardson Jr., P.E.  
Richardson Engineering  
7 Deneison Street  
Timonium, Maryland 21093

RE: McDonogh Overlook  
Stormwater Management Fee-in-Lieu  
Gwynns Falls Watershed  
**Project I.D. M180344**  
**EPS Tracking Number: 02-24-4127**

Dear Patrick Richardson Jr.:

This office has reviewed the information submitted and finds that a variance can be granted for this project under Section 33-4-113 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there were exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of this article. In approving the variance, the following conditions must be met.

This project is for a subdivision, which proposes to construct 9 single family dwellings and a public road. The limit of disturbance and proposed impervious area are 3.40 acres and 1.04 acres, respectively. The majority of impervious area is treated via two surface sand filters and non-structural practices.

1. All runoff must be conveyed to a suitable outfall without imposing an adverse impact on the receiving waterbody, watercourse, wetland, storm drain or adjacent property.
2. The total area of land disturbance must be noted on the plan, limits of disturbance must be shown on the plan.
3. As much as possible, impervious areas should be conveyed as sheet flow through vegetated areas without concentrating or causing erosion.
4. Building down spouts should be discharged onto pervious areas where feasible.
5. Additional subdivision on these parcels and/or lots will require stormwater management controls for this site and the additional subdivision.
6. A payment in the amount of **\$ 7,600.00 or \$ 40,000.00** per on-site impervious acre, in this case 0.19 acres, shall be made prior to permit issuance. This is the rate for residential properties inside the Priority Funding Area and Urban Rural Demarcation Line. The payment should be in the form of a check **payable to Baltimore County Maryland** and should be submitted to the Finance and Administration Section of this Department.

Should there be further questions, please contact Vearle Cochran, P.E. at 410 887-3768.

Very truly yours,

*/signed/*

Kritty Udhin, P.E., Manager  
Stormwater Management

KU:vc

c: Finance and Administration Section